

## STATEMENT OF BASIS

as required by LAC 33:IX.3109, for draft **Louisiana Pollutant Discharge Elimination System Permit No. LA0077917; AI 40474; PER20080001** to discharge to waters of the **State of Louisiana** as per LAC 33:IX.2311.

The **permitting authority** for the Louisiana Pollutant Discharge Elimination System (LPDES) is:

Louisiana Department of Environmental Quality  
Office of Environmental Services  
P. O. Box 4313  
Baton Rouge, Louisiana 70821-4313

- I. **THE APPLICANT IS:** Total Environmental Solutions, Inc  
The Glades  
PO Box 14056  
Baton Rouge, LA 70898
  
- II. **PREPARED BY:** Rachel Davis  
  
**DATE PREPARED:** January 7, 2009
  
- III. **PERMIT ACTION:** reissue LPDES permit LA0077917, AI 40474; PER20080001  
  
LPDES application received: June 19, 2008  
  
EPA has not retained enforcement authority.  
  
LPDES permit issued: May 1, 2004  
LPDES permit expires: April 30, 2009
  
- IV. **FACILITY INFORMATION:**
  - A. The application is for the discharge of treated sanitary wastewater from an existing privately owned treatment works serving the The Glades Subdivision.
  - B. The permit application does not indicate the receipt of industrial wastewater.
  - C. The facility is located off Wildfire Rd; off Glade Blvd; off Duhon Rd; off US 167 in Lafayette, Lafayette Parish.
  - D. The treatment facility consists of an extended aeration treatment plant with chlorine disinfection.
  - E. Outfall 001

Discharge Location: Latitude 30° 9' 5" North  
Longitude 92° 06' 22" West

Description: treated sanitary wastewater

Expected Flow: 151 homes x 400 gallons/day/home = 0.0604 MGD

Calculations for gallons per day were based upon figures obtained from Chapter 15 of the State of Louisiana Sanitary Code, Department of Health and Hospitals, Office of Public Health.

Type of Flow Measurement which the facility is currently using:  
V-Notch Weir or stopwatch and bucket

## Statement of Basis

LA0077917; AI 40474; PER20080001

Page 2

**V. RECEIVING WATERS:**

The discharge is into an unnamed ditch, thence into Coulee Ile des Cannes, thence into the Vermilion River in segment 060802 of the Vermilion Teche River Basin. This segment is not listed on the 303(d) list of impaired waterbodies.

The designated uses and degree of support for Segment 060802 of the Vermilion Teche River Basin are as indicated in the table below<sup>1/</sup>:

Degree of Support of Each Use						
Primary Contact Recreation	Secondary Contact Recreation	Propagation of Fish & Wildlife	Outstanding Natural Resource Water	Drinking Water Supply	Shell fish Propagation	Agriculture
Not Supported	Not Supported	Not Supported	N/A	N/A	N/A	Full

<sup>1/</sup>The designated uses and degree of support for Segment 060802 of the Vermilion Teche River Basin are as indicated in LAC 33:IX.1123.C.3, Table (3) and the 2006 Water Quality Management Plan, Water Quality Inventory Integrated Report, Appendix A, respectively.

**VI. ENDANGERED SPECIES:**

The receiving waterbody, Subsegment 060802 of the Vermilion-Teche River Basin, is not listed in Section II.2 of the Implementation Strategy as requiring consultation with the U. S. Fish and Wildlife Service (FWS). This strategy was submitted with a letter dated November 24, 2008 from Rieck (FWS) to Nolan (LDEQ). Therefore, in accordance with the Memorandum of Understanding between the LDEQ and the FWS, no further informal (Section 7, Endangered Species Act) consultation is required. It was determined that the issuance of the LPDES permit is not likely to have an adverse effect on any endangered or candidate species or the critical habitat. The effluent limitations established in the permit ensure protection of aquatic life and maintenance of the receiving water as aquatic habitat.

**VII. HISTORIC SITES:**

The discharge is from an existing facility location, which does not include an expansion beyond the existing perimeter. Therefore, there should be no potential effect to sites or properties on or eligible for listing on the National Register of Historic Places, and in accordance with the 'Memorandum of Understanding for the Protection of Historic Properties in Louisiana Regarding LPDES Permits' no consultation with the Louisiana State Historic Preservation Officer is required.

**VIII. PUBLIC NOTICE:**

Upon publication of the public notice, a public comment period shall begin on the date of publication and last for at least 30 days thereafter. During this period, any interested persons may submit written comments on the draft permit and may request a public hearing to clarify issues involved in the permit decision at this Office's address on the first page of the statement of basis. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing.

## Statement of Basis

LA0077917; AI 40474; PER20080001

Page 3

Public notice published in:

Local newspaper of general circulation

Office of Environmental Services Public Notice Mailing List

For additional information, contact:

Ms. Rachel Davis  
 Water Permits Division  
 Department of Environmental Quality  
 Office of Environmental Services  
 P. O. Box 4313  
 Baton Rouge, Louisiana 70821-4313

**IX. PROPOSED PERMIT LIMITS:****Final Effluent Limits:**

Subsegment 060802, is not listed on LDEQ's Final 2006 303(d) List as impaired. However, subsegment 060802 was previously listed as impaired for phosphorus, nitrogen, organic enrichment/low DO, pathogen indicators, suspended solids/turbidity/ siltation, and carbofuran for which the below TMDL's have been developed. The Department of Environmental Quality reserves the right to impose more stringent discharge limitations and/or additional restrictions in the future to maintain the water quality integrity and the designated uses of the receiving water bodies based upon additional TMDL's and/or water quality studies. The DEQ also reserves the right to modify or revoke and reissue this permit based upon any changes to established TMDL's for this discharge, or to accommodate for pollutant trading provisions in approved TMDL watersheds as necessary to achieve compliance with water quality standards.

The following TMDLs have been established for subsegment 060802:

**1999 Review and Assessment of the 1987 Vermilion River Watershed TMDL for Dissolved Oxygen**

This TMDL was revised in December 1999, and approved by EPA on April 5, 2001. This TMDL re-established that NPDES permits for individual point sources in the Vermilion Watershed should continue to be issued on the basis of flow rates as follows:

<u>FLOW RATE</u>	<u>PERMIT LIMITS</u>
greater than 25,000 gpd	May – Dec.: 10 mg/l CBOD <sub>5</sub> /5 mg/l NH <sub>3</sub> -N/5 mg/l DO
25,000 gpd or less	Jan.- April: 20 mg/l CBOD <sub>5</sub> /10 mg/l NH <sub>3</sub> -N/5 mg/l DO secondary limits year round

Therefore, this discharge will be permitted accordingly.

**Vermilion River TMDL for Fecal Coliform**

The *Vermilion River TMDL for Fecal Coliform* was finalized on April 5, 2001, addressing the presence of pathogen indicators in the watershed. As per this TMDL, "...there will be no change in the permit requirements based upon a wasteload allocation resulting from this TMDL." Therefore, Fecal Coliform effluent limitations will be permitted according to the current state policy.

## Statement of Basis

LA0077917; AI 40474; PER20080001

Page 4

TMDL for TSS, Turbidity, and Siltation for the 15 Subsegments in the Vermilion River Basin

As per the TMDL for TSS, Turbidity, and Siltation for the 15 Subsegments in the Vermilion River Basin, "point source loads are so small as to be insignificant, and because effective policies are in place to limit TSS discharges, no specific reductions from point sources are required." Therefore, TSS limits will be established in this general permit according to the current state standards.

TMDL for the Pesticide Carbofuran in the Mermentau and Vermilion-Teche River Basins

The TMDL for the Pesticide Carbofuran in the Mermentau and Vermilion-Teche River Basins was finalized on March 21, 2002, and states no point sources are known to discharge Carbofuran; therefore, no allocation was given to point source discharges in the Vermilion-Teche River Basin

**OUTFALL 001**

Final limits shall become effective on the effective date of the permit and expire on the expiration date of the permit.

Effluent Characteristic	Monthly Avg. (lbs./day)	Monthly Avg	Daily Max	Basis
CBOD <sub>5</sub> May-December January-April		10 mg/l 20 mg/l	15 mg/l 30 mg/l	Based on the <u>1999 Review and Assessment of the 1987 Vermilion River Watershed TMDL for Dissolved Oxygen</u> for dischargers over 25,000 GPD
TSS May-December January-April		15 mg/l 20 mg/l	23 mg/l 30 mg/l	Since there is no numeric water quality criterion for TSS, and in accordance with the current Water Quality Management Plan, the TSS effluent limitations shall be based on a case-by-case evaluation of the treatment technology being utilized at a facility. Therefore, a Technology Based Limit has been established through Best Professional Judgement for the type of treatment technology utilized at this facility.
Ammonia-Nitrogen May-December January-April		5 mg/l 10 mg/l	10 mg/l 20 mg/l	Based on the <u>1999 Review and Assessment of the 1987 Vermilion River Watershed TMDL for Dissolved Oxygen</u> for dischargers over 25,000 GPD
Dissolved Oxygen*		5.0 mg/l	N/A	Based on the <u>1999 Review and Assessment of the 1987 Vermilion River Watershed TMDL for Dissolved Oxygen</u> for dischargers over 25,000 GPD

\*This Dissolved Oxygen limit is the lowest allowable average of daily discharges over a calendar month. When monitoring is conducted, the Dissolved Oxygen shall be analyzed immediately, as per 40 CFR 136.3.

## Statement of Basis

LA0077917; AI 40474; PER20080001

Page 5.

**Other Effluent Limitations:****1) Fecal Coliform**

The discharge from this facility is into a water body which has a designated use of Primary Contact Recreation. According to LAC 33:IX.1113.C.5, the fecal coliform standards for this water body are 200/100 ml and 400/100 ml. Therefore, the limits of 200/100 ml (Monthly Average) and 400/100 ml (Daily Maximum) are proposed as Fecal Coliform limits in the permit. These limits are being proposed through Best Professional Judgement in order to ensure that the water body standards are not exceeded, and due to the fact that existing facilities have demonstrated an ability to comply with these limitations using present available technology.

**2) pH**

According to LAC 33:IX.3705.A.1., POTW's must treat to at least secondary levels. Therefore, in accordance with LAC 33:IX.5905.C., the pH shall not be less than 6.0 standard units nor greater than 9.0 standard units at any time.

**3) Solids and Foam**

There shall be no discharge of floating solids or visible foam in other than trace amounts in accordance with LAC 33:IX.1113.B.7.

**X. PREVIOUS PERMITS:**

LPDES Permit No. LA0077917: Issued: May 1, 2004  
Expires: April 30, 2009

<u>Effluent Characteristic</u>	<u>Discharge Limitations</u>		<u>Monitoring Requirements</u>	
	<u>Daily Avg.</u>	<u>Weekly Avg</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow	Report	Report	1/week	Measure
CBOD <sub>5</sub>				
May-December	10 mg/l	15 mg/l	2/month	Grab
January-April	20 mg/l	30 mg/l	2/month	Grab
TSS				
May-December	15 mg/l	23 mg/l	2/month	Grab
January-April	20 mg/l	30 mg/l	2/month	Grab
Ammonia-Nitrogen				
May-December	5 mg/l	10 mg/l	2/month	Grab
January-April	10 mg/l	20 mg/l	2/month	Grab
Fecal Coliform Colonies	200	400	2/month	Grab

**XI. ENFORCEMENT AND SURVEILLANCE ACTIONS:****A) Inspections**

A review of the files indicates the following inspections were performed during the period beginning **September 2006** and ending **September 2008** for this facility.

Date: May 4, 2007

Inspector: Daron Suggs

Findings and/or Violations:

## Statement of Basis

LA0077917; AI 40474; PER20080001

Page 6

1. DMR review revealed many excursions during 2006-2007 review period
2. Plant had not been visited in a few days and a limb had clogged the shimmer
3. Build up of floating sludge in the clarifier
4. Effluent was light gray

**B) Compliance and/or Administrative Orders**

A review of the files indicates that no orders have been administered against the facility in the past two years.

**C) DMR Review**

A review of the discharge monitoring reports for the period beginning **September 2006** through **September 2008** has revealed the following violations:

Period of Excursion	Parameter	Outfall	Permit Limit	Reported Quantity
September 2006	DO	001	5 mg/l	3.17 mg/l
October 2006	DO	001	5 mg/l	3.54 mg/l
	TSS		15 mg/l	98 mg/l
	TSS		23 mg/l	140 mg/l
	Ammonia		5 mg/l	6.87 mg/l
	Ammonia		10 mg/l	12.5 mg/l
November 2006	Fecal	001	400	2,100
	TSS		15 mg/l	25.5 mg/l
December 2006	TSS	001	23 mg/l	37 mg/l
	TSS		15 mg/l	30 mg/l
January 2007	TSS	001	23 mg/l	42 mg/l
	TSS		20 mg/l	29 mg/l
February 2007	TSS	001	30 mg/l	33 mg/l
	Fecal		200	894.4
March 2007	Fecal	001	400	5,000
	TSS		20 mg/l	32 mg/l
May 2007	TSS	001	30 mg/l	39 mg/l
	DO		5 mg/l	4.37 mg/l
June 2007	TSS	001	15 mg/l	42 mg/l
	TSS		23 mg/l	57 mg/l
July 2007	TSS	001	15 mg/l	55 mg/l
	TSS		23 mg/l	56 mg/l
August 2007	TSS	001	15 mg/l	16 mg/l
	TSS		23 mg/l	27 mg/l
September 2007	DO	001	5 mg/l	4.33 mg/l
	TSS		15 mg/l	44.5 mg/l
	TSS		23 mg/l	46 mg/l
October 2007	TSS	001	15 mg/l	53.5 mg/l
	TSS		23 mg/l	60 mg/l
November 2007	TSS	001	15 mg/l	27.5 mg/l
	TSS		23 mg/l	32 mg/l
December 2007	DO	001	5 mg/l	4.11 mg/l
	TSS		15 mg/l	22.5 mg/l
	TSS		23 mg/l	26 mg/l
January 2008	TSS	001	20 mg/l	26.5 mg/l
	TSS		30 mg/l	51 mg/l
February 2008	TSS	001	20 mg/l	72.5 mg/l
	TSS		30 mg/l	123 mg/l

## Statement of Basis

LA0077917; AI 40474; PER20080001

Page 7

March 2008	TSS	001	20 mg/l	33 mg/l
	TSS		30 mg/l	40 mg/l
April 2008	TSS	001	20 mg/l	78 mg/l
	TSS		30 mg/l	94 mg/l
	Fecal		200	TNTC
	Fecal		400	TNTC
June 2008	TSS	001	15 mg/l	36 mg/l
	TSS		23 mg/l	50 mg/l
July 2008	TSS	001	15 mg/l	57.5 mg/l
	TSS		23 mg/l	84 mg/l
August 2008	DO	001	5 mg/l	4.59 mg/l
	TSS		15 mg/l	20 mg/l
	TSS		23 mg/l	25 mg/l
September 2008	TSS	001	15 mg/l	28 mg/l
	TSS		23 mg/l	39 mg/l

**XII. ADDITIONAL INFORMATION:**

The Louisiana Department of Environmental Quality (LDEQ) reserves the right modify or revoke and reissue this permit based upon any changes to established TMDL's for this discharge, or to accommodate for pollutant trading provisions in approved TMDL watersheds as requested by the permittee and/or as necessary to achieve compliance with water quality standards. Therefore, prior to upgrading or expanding this facility, the permittee should contact the Department to determine the status of the work being done to establish future effluent limitations and additional permit conditions.

This permit may be modified, or alternatively, revoked and reissued, to comply with any applicable effluent standard or limitations issued or approved under sections 301(b)(2)(C) and (D); 304(b)(2); and 307(a)(2) of the Clean Water Act or more stringent discharge limitations and/or additional restrictions in the future to maintain the water quality integrity and the designated uses of the receiving water bodies based upon additional water quality studies and/or TMDL's, if the effluent standard, limitations, water quality studies or TMDL's so issued or approved:

- a) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
- b) Controls any pollutant not limited in the permit; or
- c) Requires reassessment due to change in 303(d) status of waterbody; or
- d) Incorporates the results of any total maximum daily load allocation, which may be approved for the receiving water body.

Please be aware that the Department has the authority to reduce monitoring frequencies when a permittee demonstrates two or more consecutive years of permit compliance. Monitoring frequencies established in LPDES permits are based on a number of factors, including but not limited to, the size of the discharge, the type of wastewater being discharged, the specific operations at the facility, past compliance history, similar facilities and best professional judgment of the reviewer. We encourage and invite each permittee to institute positive measures to ensure continued compliance with the LPDES permit, thereby qualifying for reduced monitoring frequencies upon permit reissuance. If the Department can be of any assistance in this area, please do not hesitate to contact us. As a reminder, the Department will also consider an increase in monitoring frequency upon permit reissuance when the permittee demonstrates continued non-compliance.

## Statement of Basis

LA0077917; AI 40474; PER20080001

Page 8

At present, the **Monitoring Requirements, Sample Types, and Frequency of Sampling** shall remain as previously permitted:

<u>Effluent Characteristics</u>	<u>Monitoring Requirements</u>	
	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow	1/week	Measure
CBOD <sub>5</sub>	2/month	Grab
Total Suspended Solids	2/month	Grab
Ammonia-Nitrogen	2/month	Grab
Dissolved Oxygen	2/month	Grab
Fecal Coliform Bacteria	2/month	Grab
pH	2/month	Grab

### XIII. TENTATIVE DETERMINATION:

On the basis of preliminary staff review, the Department of Environmental Quality has made a tentative determination to reissue a permit for the discharge described in this Statement of Basis.

### XIV. REFERENCES:

Louisiana Water Quality Management Plan / Continuing Planning Process, Vol. 8, "Wasteload Allocations / Total Maximum Daily Loads and Effluent Limitations Policy," Louisiana Department of Environmental Quality, 2005.

Louisiana Water Quality Management Plan / Continuing Planning Process, Vol. 5, "Water Quality Inventory Section 305(b) Report," Louisiana Department of Environmental Quality, 1998.

Louisiana Administrative Code, Title 33 - Environmental Quality, Part IX - Water Quality Regulations, Chapter 11 - "Louisiana Surface Water Quality Standards," Louisiana Department of Environmental Quality, 2004.

Louisiana Administrative Code, Title 33 - Environmental Quality, Part IX - Water Quality Regulations, Subpart 2 - "The LPDES Program," Louisiana Department of Environmental Quality, 2004.

Low-Flow Characteristics of Louisiana Streams, Water Resources Technical Report No. 22, United States Department of the Interior, Geological Survey, 1980.

Index to Surface Water Data in Louisiana, Water Resources Basic Records Report No. 17, United States Department of the Interior, Geological Survey, 1989.

LPDES Permit Application to Discharge Wastewater, Total Environmental Solutions, Inc, The Glades, August 8, 2008.